

TAPPING SLEEVES, VALVES AND VALVE BOXES ON WATER LINES

630.6 AIR RELEASE AND VACUUM VALVES:

Valve assemblies shall be furnished and installed where shown and as detailed on the drawings.

(A) Air release on water mains shall be controlled by the use of an air release valve assembly, or size and type as shown on the plans. Air release valves shall be of the flanged or screwed type as shown and shall be similar and equal to Apco, Crispin, A.R.I. or Simplex.

(B) Vacuum and Air Relief when called for on the plans shall be controlled by a vacuum relief valve on the air release valve noted above and the valves shall be of the same manufacture or may be a combination air and vacuum valve assembly similar and equal to Apco, Crispin, A.R.I. or Simplex.