



---

MEMORANDUM

Date: 2/6/08

To: Robert Herz

From: Peter Kandarlis

Re: MAG Case 08-01 – Suggested Changes and Comments

In addition to the suggested changes, SRP recommends the following additional requirements be included for import borrow:

- Suitable fill shall meet the following requirements:
  - (a) Liquid Limit (LL), per ASTM D4318, less than 50.
  - (b) Can be field compacted to at least the specified minimum densities.
- All borrow material for fill shall be stable, meet compaction requirements and be acceptable to the Engineer. Unstable material includes silt and clay soils with a moisture content so significantly over optimum that cannot be compacted to the required maximum density.